

Emergency Equipment and Information



- Major hazards in this lab/workshop.
- Person in charge and their contact details.
- Other emergency contact information.
- The color- coded system on the top right for the level of access control for janitorial staff.
- PPE you need to wear when in this lab.

What information is on my LAB DOOR SIGNAGE?

Update door sign when there are changes to the person in charge, contact information and hazard.

<https://www.clemson.edu/research/safety/lab-door.html>

Does my area need a SAFETY SHOWER/EYEWASH?

Where the eyes or body of a person may be exposed to injurious corrosive materials, chemicals, disinfectants, or other hazardous substances, suitable facilities for quick drenching or flushing of the eyes and body shall be provided within the work area for immediate emergency use.



Monthly: Test & inspect the safety shower.

Weekly: Test & inspect the eyewash.

Record test results on log.



Monthly: Occupants perform a visual inspection & document on the portable fire extinguishers tag. Be sure that the pressure gauge or indicator (if present) is in the operable range or position and the pin is in place.

Annually: Fire extinguisher inspection performed by a fire protection company.

How often do I need to check the FIRE EXTINGUISHER?



Report Near Misses (Nice Catch)

- * To share close calls and near misses in order to alert others.
- * To share your experiences with the Office of Research Safety to help improve the safety culture at Clemson University.

For IOS Devices

APP can be downloaded: <https://mobile.app.clemson.edu>