

# Common Lab Inspection Findings

## Training

- PIs and Lab Personnel must complete all training required by Research Safety.

## Labeling

- All chemical containers and storage areas must be properly labeled.

## Check Safety Equipment

- The Safety Shower must be tested monthly, and the Eyewash weekly.
- Fire Extinguisher visual inspections must be done monthly.

## Chemical Segregation

- Properly segregate incompatible chemicals. A storage guide can be found on the RS website.



OCCUPATIONAL AND  
ENVIRONMENTAL SAFETY

<http://www.clemson.edu/research/safety>

## Remember

Update Lab  
Door Signs

---

Read & Sign  
the CHP

---

Gas  
Cylinders:  
Chains not  
Straps

---

Contact RS  
before use  
of  
respirators/  
dust masks