January 7, 2019

Clemson University
310 Klugh Avenue
Clemson, South Carolina 29634

Attn: Mr. W. Robert Newberry, IV
E-mail: wnewber@clemson.edu

Re: Limited Mold and Allergen Investigation Report
Clemson University
ICAR – 4th and 5th Floor Office Space
Greenville, South Carolina
Terracon Project No. 86187189E

Dear Mr. Newberry:

Terracon Consultants, Inc. (Terracon) conducted a limited mold and allergen investigation in the 4th and 5th Floor offices of the International Center for Automotive Research (ICAR) building in Greenville, South Carolina. This service was conducted in general accordance with our Master Service Agreement with Clemson University.

PROJECT DESCRIPTION

Scope of Services

At the request of Clemson University, Terracon conducted a limited mold and allergen investigation in the 4th and 5th Floor offices of the ICAR building on December 13, 2018. Reportedly, there were some concerns of indoor air quality issues, and Clemson wishes to test the area for mold and allergens.

On our December 13th visit, Terracon made measurements of temperature and relative humidity and conducted airborne mold sampling which consisted of collecting spore trap air samples in four locations inside the office areas and the collection of two additional samples outside for comparison. We also collected two composite microvac dust samples for allergen analysis.

Standard of Care

This limited mold and allergen investigation was conducted in a manner consistent with the level of care and skill ordinarily exercised by members of the profession currently practicing under similar conditions in the same locale. Terracon did not attempt to identify every potential exposure or hazard present in the subject building. The results, findings, conclusions and recommendations expressed in this report are based on conditions observed during our sampling. Many factors, such as weather conditions, building occupancy, ventilation patterns and seasonal variations in fungal concentrations, can affect the conditions observed. The information contained in this report should not be relied upon to represent conditions that existed prior to or after this sampling. Terracon does not warrant the services of regulatory agencies, laboratories or other third parties supplying information that may have been used in the preparation of this report.

SAMPLING CRITERIA AND METHODS

Mold and Allergen Sampling

Total mold spore trap samples were collected using Air-O-Cell™ spore trap cassettes specifically designed for the collection of airborne mold spores. Air samples were collected using a calibrated Zefon Bio-Pump™ at a flow rate of 15 liters per minute (LPM) for 5 minutes at each location.

After collection, the spore trap samples were delivered by overnight courier to EMSL in Cinnaminson, New Jersey. EMSL is accredited by the AIHA® Laboratory Accreditation Programs, LLC under the Environmental Microbiology Laboratory Accreditation Program (EMLAP), Accreditation #100194. Air samples were analyzed by direct microscopic examination and results are reported in spores per cubic meter of air (spores/m^3).

To help interpret the mold sampling results, we compared indoor air and outdoor air measurements. High variability in airborne fungal spore concentrations can exist in different geographic locations, during different seasons, and weather patterns, and over the course of a given day. As a general rule, indoor air fungal spore concentrations in a heating, ventilation and air-conditioning (HVAC)-supplied building are typically less than, but qualitatively similar to, fungal spore concentrations found in the outside environment.

No state or federal exposure limits have been established for fungal aerosols. Regulatory standards, medically based threshold limit or dose-response relationships have not been established for exposure to airborne or surface concentrations of mold spores. Terracon relies upon experience, professional judgment, current scientific literature, guidelines and recommendations made by professional organizations and experts, and statistical methods in interpreting mold sampling results.

Two composite allergen dust samples were collected from carpeting in Office 405 and the 5th Floor Conference Room, using a high volume air sampling pump in conjunction with a 3-piece 37 millimeter dust sampling cassette preloaded with a 5.0 micrometer polyvinyl chloride (PVC) filter.

After composite dust sample collection, the allergen sample was shipped by overnight courier to EMSL in Cinnaminson, New Jersey. EMSL is accredited by the AIHA® Laboratory Accreditation Programs, LLC under the Environmental Microbiology Laboratory Accreditation Program (EMLAP), Accreditation #100194. Allergen samples were analyzed by direct microscopic examination for allergens from dust mites, mouse, rat, cat, dog, and cockroach. Allergen results are reported in micrograms per gram of dust (µg/g).

Temperature and Relative Humidity

Indoor air temperature and relative humidity are physical conditions important to the perception of comfort. The American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE) has published recommendations regarding thermal comfort. ASHRAE Standard 55, Thermal Environmental Conditions for Human Occupancy, identifies six primary factors that affect comfort: metabolic rate (affected by the activity being performed); clothing insulation; air temperature; radiant temperature; air speed; and humidity.

Although the relationships are complex, a temperature range between 73 and 79 degrees Fahrenheit (°F) with relative humidity between roughly 20 and 60 percent (%) are recommended for persons in a conditioned setting wearing light summer clothing. Higher temperatures require lower humidity for comfort. For persons in winter clothing, temperatures can range between 68 and 75°F, with relative humidity between 20% and 60%, with preferred conditions falling between 30% and 50% for both winter and summer temperatures. EPA recommends maintaining indoor humidity below 60%, ideally 30-50%, if possible.

Readings of temperature and relative humidity were collected with an Extech Model 445580 IAQ instrument which was calibrated by the manufacturer.

FINDINGS

General Observations

- The roof mounted heating, ventilation, and air conditioning system serves all 6 floors of the building.
- The HVAC unit cycles on and off on the 2nd through 5th floors during the evening for energy savings.
- The office spaces on both the 4th and 5th floors appeared to be very clean.
- No signs of ongoing moisture infiltration or mold growth were observed within the office spaces.

- No odd odors were noted at the time of the assessment.
- Residual water marks were noted on the seals of the exterior windows in Office 405. Although uncertain, this could be from condensation or a leaking window.
- Photographs from the assessment are attached.

Mold Air Sampling

On the morning of December 13, 2018, Terracon collected four mold spore trap samples inside the building and two samples in outdoor locations for comparison. The results of the total spore count samples analyses are summarized in Table 1 below:

Table 1: Summary of Total Spore Count Analyses in the Air – December 13, 2018

Sample #	ICR-A1	ICR-A2	ICR-A3	ICR-A4	ICR-O1	ICR-O2
Location Description	**Office 405**	**4th Floor Foyer**	**Cubicle 510**	**5th Floor Conference Room**	**Outdoors #1**	**Outdoors #2**
Spore Type	**Spores/m³**	**Spores/m³**	**Spores/m³**	**Spores/m³**	**Spores/m³**	**Spores/m³**
Alternia	--	10	--	--	--	--
Ascospores	--	--	--	40	40	40
Aspergillus/Penicillium	90	--	--	--	300	610
Basidiospores	300	40	480	300	6,940	3,400
Cladosporium	40	--	--	40	960	200
Myxomycetes	--	--	--	--	40	40
Rust	--	--	--	--	--	40
Total	**430**	**50**	**480**	**380**	**8,280**	**4,330**
Temperature (degrees F.)	70.9	71.2	72.8	73.0	41.2	54.1
Relative Humidity (%)	43.5	46.7	39.8	38.1	52.8	41.8

The total mold spore levels indoors were lower than the outdoor levels. With the predominant mold type identified indoors and outdoors as Basidiospores. The laboratory analytical report is attached.

Temperature and Relative Humidity

The average indoor temperature was 72.0ºF and the relative humidity was 42.0%. The average outdoor temperature was 47.7ºF and the relative humidity was 47.3%.

Allergen Sampling

On December 13, 2018, Terracon collected two dust samples from the carpeting in Office 405 and the 5th Floor Conference Room. The samples were analyzed for allergens from dust mites, mouse, rat, cat, dog, and cockroach.

Allergens were identified in the samples. Table 2 below summarizes the laboratory results. The laboratory analytical report is attached and references additional information.

Table 2: Summary of Allergen Analyses – December 13, 2018

Sample #	ICR-CV1		ICR-CV2	
Location Description	**Room 405**		**5th Floor Conference Room**	
Allergen Type/Antigen	**Concentration (ug/g)**	**Laboratory assigned risk factor**	**Concentration (ug/g)**	**Laboratory assigned risk factor**
Dust Mites / Der fl	ND	Low	ND	Low
Dust Mites / Der pl	ND	Low	ND	Low
Mouse / Mus ml	ND	Low	ND	Low
Rat / Rat nl	ND	N/A	ND	N/A
Cat / Fel dl	0.29	Low	0.60	Low
Dog / Can fl	0.13	Low	0.59	Low
Cockroach / Bla G2	ND	Low	ND	Low

Note: ug = microgram (10^{-6} grams), NA = Not Applicable, ND = not detected

CONCLUSIONS/RECOMMENDATIONS

The following conclusions/recommendations are provided based on our assessment:

- Based upon visual observations, the 4th and 5th floor office areas appeared to be clean and had no signs of ongoing moisture intrusion or mold growth.
- Residual water stains were noted on the window seals in Office 405. Although uncertain, this could be from condensation or a leaking window.
- Temperature and humidity measurements showed the indoors were within the ASHRAE recommended ranges for fall/winter.
- Results of the spore trap sampling, showed that the indoors had mold spores at a lower concentration compared to the outdoors. Additionally the mold spores appeared to be of the same type in both the indoor and outdoor samples.
- Carpet vacuum samples indicated low level allergens (cat and dog) were observed within the area tested, and were characterized as a low risk level by the laboratory.

Terracon appreciates the opportunity to provide this service to Clemson University. If you have any questions regarding this limited mold and allergen investigation report, please contact the undersigned at 864-292-2901.

Sincerely,
Terracon Consultants, Inc.

Stephen N. Ellis
Staff Industrial Hygienist

Charlie Sean FOR:
Jeffrey A. Gurrie, CIH
Senior Industrial Hygienist

Attachments: Photographs
Laboratory Results

Photographs




Photo #1 General view of the 4th floor foyer area.



Photo #2 General view of the 4th floor foyer area.



Photo #3 General view of the 5th floor hallway.



Photo #4 General view of the 5th floor conference room.



Photo #5 General view of Office 405.



Photo #6 General view of residual water marks/staining along the window seals in Office 405.

Laboratory Results

EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
http://www.EMSL.com / cinnmicrolab@emsl.com

EMSL Order: 371823035
Customer ID: GTER78
Customer PO: 86187189E
Project ID:

Attn: Jeff Gurrie
Terracon Consultants, Inc.
72 Pointe Circle
Greenville, SC 29615


Phone: (864) 360-7572
Fax: (864) 292-6361
Collected: 12/13/2018
Received: 12/14/2018
Analyzed: 12/15/2018

Project: 86187189E CU ICAR 4th Floor

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	371823035-0001			371823035-0002			371823035-0003		
Client Sample ID:	ICR-A1			ICR-A2			ICR-A3		
Volume (L):	75			75			75		
Sample Location	Rm 405			4th Floor Foyer			Cubicle 510		
Spore Types	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	-	-	-	1*	10*	20	-	-	-
Ascospores	-	-	-	-	-	-	-	-	-
Aspergillus/Penicillium	2	90	20.9	-	-	-	-	-	-
Basidiospores	7	300	69.8	1	40	80	11	480	100
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	1	40	9.3	-	-	-	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	**10**	**430**	**100**	**2**	**50**	**100**	**11**	**480**	**100**
Hyphal Fragment	-	-	-	1	40	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.



Vincent Iuzzolino, M.S., Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Lab 100194

Initial report from: 12/17/2018 09:44:06

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
http://www.EMSL.com / cinnmicrolab@emsl.com

EMSL Order: 371823035
Customer ID: GTER78
Customer PO: 86187189E
Project ID:

Attn: Jeff Gurrie
Terracon Consultants, Inc.
72 Pointe Circle
Greenville, SC 29615


Phone: (864) 360-7572
Fax: (864) 292-6361
Collected: 12/13/2018
Received: 12/14/2018
Analyzed: 12/15/2018

Project: 86187189E CU ICAR 4th Floor

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	371823035-0004			371823035-0005			371823035-0006		
Client Sample ID:	ICR-A4			ICR-O1			ICR-O2		
Volume (L):	75			75			75		
Sample Location	5th Floor Conference Room			Outdoors 1			Outdoors 2		
Spore Types	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	1	40	10.5	1	40	0.5	1	40	0.9
Aspergillus/Penicillium	-	-	-	7	300	3.6	14	610	14.1
Basidiospores	6	300	78.9	159	6940	83.8	79	3400	78.5
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	1	40	10.5	22	960	11.6	4	200	4.6
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	1	40	0.5	1	40	0.9
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	1	40	0.9
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Total Fungi	**8**	**380**	**100**	**190**	**8280**	**100**	**100**	**4330**	**100**
Hyphal Fragment	-	-	-	-	-	-	1	40	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	2	90	-	-	-	-
Analyt. Sensitivity 600x	-	44	-	-	44	-	-	44	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.



Vincent Iuzzolino, M.S., Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Lab 100194

Initial report from: 12/17/2018 09:44:06

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

EMSL Analytical, Inc.

200 Route 130 North Cinnaminson, NJ 08077
Tel/Fax: (800) 220-3675 / (856) 786-0262
http://www.EMSL.com / cinnmicrolab@emsl.com

EMSL Order: 371823035
Customer ID: GTER78
Customer PO: 86187189E
Project ID:

Attn: Jeff Gurrie
Terracon Consultants, Inc.
72 Pointe Circle
Greenville, SC 29615


Phone: (864) 360-7572
Fax: (864) 292-6361
Collected: 12/13/2018
Received: 12/14/2018
Analyzed: 12/15/2018

Project: 86187189E CU ICAR 4th Floor

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:		371823035-0007	
Client Sample ID:		BL	
Volume (L):			
Sample Location		Blank	
Spore Types	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	-	-	-
Ascospores	-	-	-
Aspergillus/Penicillium	-	-	-
Basidiospores	-	-	-
Bipolaris++	-	-	-
Chaetomium	-	-	-
Cladosporium	-	-	-
Curvularia	-	-	-
Epicoccum	-	-	-
Fusarium	-	-	-
Ganoderma	-	-	-
Myxomycetes++	-	-	-
Pithomyces++	-	-	-
Rust	-	-	-
Scopulariopsis/Microascus	-	-	-
Stachybotrys/Memnoniella	-	-	-
Unidentifiable Spores	-	-	-
Zygomycetes	-	-	-
Total Fungi	**-**	**No Trace**	**-**
Hyphal Fragment	-	-	-
Insect Fragment	-	-	-
Pollen	-	-	-
Analyt. Sensitivity 600x	-	0	-
Analyt. Sensitivity 300x	-	0*	-
Skin Fragments (1-4)	-	-	-
Fibrous Particulate (1-4)	-	-	-
Background (1-5)	-	-	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.



Vincent Iuzzolino, M.S., Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC--EMLAP Lab 100194

Initial report from: 12/17/2018 09:44:06

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800)220-3675 / (856)786-0262
http://www.EMSL.com cinnmicrolab@emsl.com

EMSL Order #:	**371823035**
Customer ID:	**GTER78**
Customer PO:	**86187189E**


Attn: **Jeff Gurrie**
Terracon Consultants, Inc.
72 Pointe Circle
Greenville, SC 29615

Phone: **864-292-2901**
Fax: **864-292-6361**

Project: **86187189E CU ICAR 4th Floor**

Date Collected: **12/13/2018**
Date Received: **12/14/2018**
Date Analyzed: **12/17/2018**

Sample Summary -Indoor Allergen Analysis by MARIA®



Lab Sample Number	Client Sample ID	Sample Location	Sample Type
371823035-0008	ICR-CV1	Rm 405	Bulk
371823035-0009	ICR-CV2	5th Floor Conference Room	Bulk

Report Date	Report Revision	Revision Comments
12/18/2018	R0	Initial Report

Vincent Iuzzolino, M.S., Laboratory Director
or approved EMSL Analytical, Inc. signatory

About Us

EMSL Analytical, Inc. offers a full line of analytical solutions for over 30 years across North America. For more information about our nationally accredited locations, vast line of testing services, and our food safety solutions please visit www.EMSL.com or call



Disclaimers

All samples were collected by and all sampling data was provided by the client. The results are valid only for those samples analyzed, and only for those samples collected in accordance with the appropriate methodology as determined by the client. The results herein do not denote or represent a medical or clinical diagnosis or conclusion. In the event that sample(s) were submitted in opened, used, non-sterile or otherwise adulterated condition, EMSL shall not be responsible or liable. EMSL Analytical (Cinnaminson, NJ) is accredited by the American Industrial Hygiene Association (AIHA) in the EMLAP accreditation program for specified Field(s) of Testing as documented on the scope of accreditation.

Please visit our website at http://www.microbiologytestinglab.com/
© 2016, EMSL Analytical, Inc., All rights reserved. No part of this report may be reproduced or otherwise distributed or used without the express written consent of EMSL.

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800)220-3675 / (856)786-0262
http://www.EMSL.com cinnmicrolab@emsl.com

EMSL Order #: **371823035**
Customer ID: **GTER78**
Customer PO: **86187189E**

Attn: **Jeff Gurrie**
Terracon Consultants, Inc.
72 Pointe Circle
Greenville, SC 29615

Phone: **864-292-2901**
Fax: **864-292-6361**

Project: **86187189E CU ICAR 4th Floor**

Date Collected: **12/13/2018**
Date Received: **12/14/2018**
Date Analyzed: **12/17/2018**

EMSL Sample #: **371823035-0008**
Client ID: **ICR-CV1**
Location: **Rm 405**

Sample Type: **Bulk**
Sample Size: **39**
Sample Units: **mg**

Analytical Results -Indoor Allergen Analysis by MARIA®

Test Parameter	*Antigens*	*Detection Limits*		*Concentrations*		*Allergen Risk Levels*
Dust Mites Allergen	Der f1	0.012	µg/g	**ND**	µg/g	☑
Dust Mites Allergen	Der p1	0.012	µg/g	**ND**	µg/g	☑
Mouse Allergen	Mus m1	0.002	µg/g	**ND**	µg/g	☑
Rat Allergen	Rat n1	0.004	µg/g	**ND**	µg/g	†
Cat Allergen	Fel d1	0.004	µg/g	**0.29**	µg/g	☑
Dog Allergen	Can f1	0.012	µg/g	**0.13**	µg/g	☑
Cockroach Allergen	Bla g2	0.012	µg/g	**ND**	µg/g	☑

†Sufficient evidence is not available for risk levels.

Allergen Risk Levels:

High -Risk of acute asthmatic attack.

Moderate -Risk for sensitization and bronchial hyperactivity.

Low -Not sufficient to cause symptoms or ND (None Detected); Indicates that the amount of allergen in the sample is below the detection limits.

All samples were collected by and all sampling data was provided by the client. The results are valid only for those samples analyzed, and only for those samples collected in accordance with the appropriate methodology as determined by the client. The results herein do not denote or represent a medical or clinical diagnosis or conclusion. In the event that sample(s) were submitted in opened, used, non-sterile or otherwise adulterated condition, EMSL shall not be responsible or liable.

EMSL Analytical (Cinnaminson, NJ) is accredited by the American Industrial Hygiene Association (AIHA) in the EMLAP accreditation program for specified Field(s) of Testing as documented on the scope of accreditation.

This report has been prepared by EMSL Analytical, Inc. at the request of and for the exclusive use of the client named in this report. Completely read the important terms, conditions, and limitations that apply to this report

Report Date	**Report Revision**	**Revision Comments**
12/18/2018	R0	Initial Report

Vincent Iuzzolino, M.S., Laboratory Director
or approved EMSL Analytical, Inc. signatory

Please visit our website at http://www.microbiologytestinglab.com/
© 2016, EMSL Analytical, Inc., All rights reserved. No part of this report may be reproduced or otherwise distributed or used without the express written consent of EMSL.

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800)220-3675 / (856)786-0262
http://www.EMSL.com cinnmicrolab@emsl.com

EMSL Order #: **371823035**
Customer ID: **GTER78**
Customer PO: **86187189E**

Attn: **Jeff Gurrie**
Terracon Consultants, Inc.
72 Pointe Circle
Greenville, SC 29615

Phone: **864-292-2901**
Fax: **864-292-6361**

Project: **86187189E CU ICAR 4th Floor**

Date Collected: **12/13/2018**
Date Received: **12/14/2018**
Date Analyzed: **12/17/2018**

EMSL Sample #: **371823035-0009**
Client ID: **ICR-CV2**
Location: **5th Floor Conference Room**

Sample Type: **Bulk**
Sample Size: **40**
Sample Units: **mg**

Analytical Results -Indoor Allergen Analysis by MARIA®

Test Parameter	*Antigens*	*Detection Limits*		*Concentrations*		*Allergen Risk Levels*
Dust Mites Allergen	Der f1	0.012	µg/g	**ND**	µg/g	☑
Dust Mites Allergen	Der p1	0.012	µg/g	**ND**	µg/g	☑
Mouse Allergen	Mus m1	0.002	µg/g	**ND**	µg/g	☑
Rat Allergen	Rat n1	0.004	µg/g	**ND**	µg/g	†
Cat Allergen	Fel d1	0.004	µg/g	**0.60**	µg/g	☑
Dog Allergen	Can f1	0.012	µg/g	**0.59**	µg/g	☑
Cockroach Allergen	Bla g2	0.012	µg/g	**ND**	µg/g	☑

†Sufficient evidence is not available for risk levels.

Allergen Risk Levels:

High -Risk of acute asthmatic attack.

Moderate -Risk for sensitization and bronchial hyperactivity.

Low -Not sufficient to cause symptoms or ND (None Detected); Indicates that the amount of allergen in the sample is below the detection limits.

All samples were collected by and all sampling data was provided by the client. The results are valid only for those samples analyzed, and only for those samples collected in accordance with the appropriate methodology as determined by the client. The results herein do not denote or represent a medical or clinical diagnosis or conclusion. In the event that sample(s) were submitted in opened, used, non-sterile or otherwise adulterated condition, EMSL shall not be responsible or liable.

EMSL Analytical (Cinnaminson, NJ) is accredited by the American Industrial Hygiene Association (AIHA) in the EMLAP accreditation program for specified Field(s) of Testing as documented on the scope of accreditation.

This report has been prepared by EMSL Analytical, Inc. at the request of and for the exclusive use of the client named in this report. Completely read the important terms, conditions, and limitations that apply to this report

Report Date	**Report Revision**	**Revision Comments**
12/18/2018	R0	Initial Report

Vincent Iuzzolino, M.S., Laboratory Director
or approved EMSL Analytical, Inc. signatory

Please visit our website at http://www.microbiologytestinglab.com/
© 2016, EMSL Analytical, Inc., All rights reserved. No part of this report may be reproduced or otherwise distributed or used without the express written consent of EMSL.

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800)220-3675 / (856)786-0262
http://www.EMSL.com cinnmicrolab@emsl.com

EMSL Order #: **371823035**
Customer ID: **GTER78**
Customer PO: **86187189E**

Attn: **Jeff Gurrie**
Terracon Consultants, Inc.
72 Pointe Circle
Greenville, SC 29615

Phone: **864-292-2901**
Fax: **864-292-6361**

Project: **86187189E CU ICAR 4th Floor**

Date Collected: **12/13/2018**
Date Received: **12/14/2018**
Date Analyzed: **12/17/2018**



Guidelines to Interpretation

µg/g

Allergens	<DL	<1	1	2	3	4	5	6	7	8	9	>10
Fel d1	ND	Low	Mod	Mod	Mod	Mod	Mod	Mod	Mod	High	High	High
Can f1	ND	Low	Low	Mod	Mod	Mod	Mod	Mod	Mod	Mod	Mod	High
Der p1	ND	Low	Low	Mod	Mod	Mod	Mod	Mod	Mod	Mod	Mod	High
Der f1	ND	Low	Low	Mod	Mod	Mod	Mod	Mod	Mod	Mod	Mod	High
Mus m1	ND	Low	Mod	Mod	Mod	High	High	High	High	High	High	High

µg/m3

Rat n1	ND	<0.7 µg /m3 = Not associated with increased risk of asthma

µg/g

	<DL	<0.08	0.08	0.09	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8
Bla g2 †	ND	Low	Mod	Mod	Mod	Mod	Mod	Mod	High	High	High	High

† *Suggested levels. Not officially established.*

Note: *This report and guidelines furnish information only. Whether an individual suffers allergic symptoms or not depends on his/her medical history and previous exposure.*

References

Journal of Allergy and Clinical Immunology 1989; 83:416-427
Journal of Allergy and Clinical Immunology 1995; 96:449-456
The American review of respiratory disease 1990; 141:361-367
The American review of respiratory disease 1993; 147:573-578
Environmental Health Perspectives 2002; 110:419-425
Clinical and Experimental Allergy 1998; 28(5):537-44
Pediatric allergy-principles and practice. Mosby Inc 2003: 261-268.

Terminology

ELISA Enzyme-linked Immunosorbent Assay
MARIA® Multiplex Array for Indoor Allergens
Allergen A substance which reacts with the body's immune system to produce an allergic reaction.
Antigen A substance, foreign to the body, which stimulates the production of antibodies by the immune system.
Bla g2 *Blattella germanica* (Cockroach) allergen 2
Can f1 *Canis familiaris* (Dog) allergen 1
Der f1 *Dermatophagoides farinae* (Dust Mites) allergen 1
Der p1 *Dermatophagoides pteronyssinus* (Dust Mites) allergen 1
Detection Limits DL is the smallest amount of a substance, in this case antigens, which can be measured.
Fel d1 *Felis domesticus* (Cat) allergen 1
Mus m1 *Mus musculus* (Mouse) allergen 1
ND None detected, if any allergens are present they are below the detection limits.
Rat n1 *Rattus norvegicus* (Rat) allergen 1

Please visit our website at http://www.microbiologytestinglab.com/
© 2016, EMSL Analytical, Inc., All rights reserved. No part of this report may be reproduced or otherwise distributed or used without the express written consent of EMSL.

EMSL Analytical, Inc.
200 Route 130 North, Cinnaminson, NJ 08077
Phone/Fax: (800)220-3675 / (856)786-0262
http://www.EMSL.com cinnmicrolab@emsl.com

EMSL Order #: **371823035**
Customer ID: **GTER78**
Customer PO: **86187189E**

Attn: **Jeff Gurrie**
Terracon Consultants, Inc.
72 Pointe Circle
Greenville, SC 29615

Phone: **864-292-2901**
Fax: **864-292-6361**

Project: **86187189E CU ICAR 4th Floor**

Date Collected: **12/13/2018**
Date Received: **12/14/2018**
Date Analyzed: **12/17/2018**



Important Terms, Conditions, and Limitations

A. Sample Retention
Samples analyzed by EMSL will be retained for 60 days after analysis date. Storage beyond this period is available for a fee with written request prior to the initial 30 day period. Samples containing hazardous/toxic substances which require special handling will be returned to the client immediately. EMSL reserves the right to charge a sample disposal fee or return samples to the client.

B. Change Orders and Cancellation
All changes in the scope of work or turnaround time requested by the client after sample acceptance must be made in writing and confirmed in writing by EMSL. If requested changes result in a change in cost the client must accept payment responsibility. In the event work is cancelled by a client, EMSL will complete work in progress and invoice for work completed to the point of cancellation notice. EMSL is not responsible for holding times that are exceeded due to such changes.

C. Warranty
EMSL warrants to its clients that all services provided hereunder shall be performed in accordance with established and recognized analytical testing procedures and with reasonable care in accordance with applicable federal, state and local laws. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied. EMSL disclaims any other warranties, express or implied, including a warranty of fitness for particular purpose and warranty of merchantability.

D. Limits of Liability
In no event shall EMSL be liable for indirect, special, consequential, or incidental damages, including, but not limited to, damages for loss of profit or goodwill regardless of the negligence (either sole or concurrent) of EMSL and whether EMSL has been informed of the possibility of such damages, arising out of or in connection with EMSL's services thereunder or the delivery, use, reliance upon or interpretation of test results by client or any third party. We accept no legal responsibility for the purposes for which the client uses the test results. EMSL will not be held responsible for the improper selection of sampling devices even if we supply the device to the user. The user of the sampling device has the sole responsibility to select the proper sampler and sampling conditions to insure that a valid sample is taken for analysis. Any resampling performed will be at the sole discretion of EMSL, the cost of which shall be limited to the reasonable the original sample delivery group (SDG) samples. In no event shall EMSL be liable to a client orvalue of any third party, whether based upon theories of tort, contract or any other legal or equitable theory, in excess of the amount paid to EMSL by client thereunder.

E. Indemnification
Client shall indemnify EMSL and its officers, directors and employees and hold each of them harmless for any liability, expense or cost, including reasonable attorney's fees, incurred by reason of any third party claim in connection with EMSL's services, the test result data or its use by client.

This report has been prepared by EMSL Analytical, Inc. at the request of and for the exclusive use of the client named in this report. Completely read the important terms, conditions, and limitations that apply to this report.

Report Date	Report Revision	Revision Comments
12/18/2018	R0	Initial Report

Vincent Iuzzolino, M.S., Laboratory Director
or approved EMSL Analytical, Inc. signatory

Please visit our website at http://www.microbiologytestinglab.com/
© 2016, EMSL Analytical, Inc., All rights reserved. No part of this report may be reproduced or otherwise distributed or used without the express written consent of EMSL.

OrderID: 371823035

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

RECEIVED
EMSL
CINNAMINSON, N.J.
2018 DEC 14 A 11:09

Microbiology Chain of Custody

EMSL Order Number (*Lab Use Only*): 371823035

Company Name: Terracon Consultants, Inc.		**EMSL-Bill to:** ☐ Same ☐ Different If Bill to is Different note instructions in Comments** *Third Party Billing requires written authorization from third party*	
Street: 72 Pointe Circle			
City: Greenville	**State/Province:** SC	**Zip/Postal Code:** 29615	**Country:** US
Report To (Name): Jeff Gurrie		**Telephone #:** 864.292.2901	
Email Address: jeff.gurrie@terracon.com		**Fax #:** 864.292.6361	**Purchase Order:**
Project Name/Number: 86187189E CU ICAR 4th Floor		**Please Provide Results:** ☐ Fax ☑ Email	
U.S. State Samples Taken: SC	**Project Zip Code:**	**Connecticut Samples:** ☐ Commercial ☐ Residential	

**Analysis completed in accordance with EMSL's Terms and Conditions located in the Analytical Price Guide. TATs are subject to methodology requirements*

Sterile, Sodium Thiosulfate Preserved Bottle Used: ☐ **Biocide Used in Source (specify):** _____ ☐

Public Water Supply Samples: ☐ **Note: All results may automatically be reported to DOH if required by state.**

Turnaround Time (TAT) Options * - Please Check

☐ 3 Hour	☐ 6 Hour	☑ 24 Hour	☐ 48 Hour	☐ 72 Hour	☐ 96 Hour	☑ 1 Week	☐ 2 Week

AOC

Microbiology Test Codes

Allergens

M001 Air-O-Cell	**M174** MoldSnap
M030 Micro 5	**M032** Allergenco-D

M041 Fungal Direct Examination
M169 Pollen ID & Enumeration
M280 Dust Characterization Level-1
M281 Dust Characterization Level-2
M005 Viable Fungi- Air Samples (Genus ID & Count)
M006 Viable Fungi- Air Samples (Includes *Penicillium, Aspergillus, Cladosporium, Stachybotrys* Species ID & Count)
M007 Culturable fungi - Surface Samples (Genus ID & Count)
M008 Culturable fungi - Surface Samples (Includes *Penicillium, Aspergillus, Cladosporium, Stachybotrys* Species ID & Count)
M009 Bacteria Culture Gram Stain & Count
M010 Bacteria Count & ID - 3 Most Prominent
M011 Bacteria Count & ID - 5 Most Prominent
M012 Pseudomonas aeruginosa (P/A***)

M024 Pseudomonas aeruginosa (MFT*)
M015 Heterotrophic Plate Count
M017 Total Coliform & E. coli (Colilert P/A***)
M018 Total Coliform & E. coli (MFT*)
M114 Total Coliform & E. coli Enumeration (Colilert MPN**)
M019 Fecal Coliform (MFT*)
M020 Fecal Streptococcus (MFT*)
M029 Enterococci (MFT*)
M129 Enterococci (Enterolert P/A***)
M180 Real Time qPCR-ERMI 36 Panel
M025 Sewage Screen –Water (MFT*)

M115 Sewage Screen - Water (P/A***)
M116 Sewage Screen - Water (MPN**)
M117 Sewage Screen - Swab (P/A***)
M013 Sewage Screen - Swab (MFT*)
M133 Methicillin-resistant Staph. aureus (MRSA)
M031 Rapid-growing non-TB Mycobacteria Detection & Enumeration
M014 Endotoxin Analysis
M044 Group Allergen (Cat, Dog, Cockroach, Dust Mite)
Other See Analytical Price Guide
Legionella Analysis Please use EMSL Legionella COC

*MFT= Membrane Filtration Technique
**MPN= Most Probable Number
***P/A= Presence/Absence

Name of Sampler: Stephen Ellis **Signature of Sampler:**

Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable (only for waters)	Test Code	Volume/ Area	Date/Time Collected	Temperature (°C) (Lab Use Only)
Example A1	Kitchen Sink/Tap	Water	☒ P ☐ NP	M017	100 mL	9/1/13 4:00 PM	
ICR-A1	Rm 405	Air	☐ P ☐ NP	M001	75L	12-13-18	
ICR-A2	4th Floor Foyer	Air	☐ P ☐ NP	M001	75L	12-13-18	
ICR-A3	Cubicle 510	Air	☐ P ☐ NP	M001	75L	12-13-18	
ICR-A4	5th Floor Conference Room	Air	☐ P ☐ NP	M001	75L	12-13-18	
ICR-O1	Outdoors 1	Air	☐ P ☐ NP	M001	75L	12-13-18	
ICR-O2	Outdoors 2	Air	☐ P ☐ NP	M001	75L	12-13-18	

Client Sample # (s): **Total # of Samples:** 9 **Samples Received Chilled? Yes / No**

Relinquished (Client): **Date:** 12-13-18 **Time:** 1400

Received (Lab): **Date:** 12/14/18 **Time:** 0930

Comments/Special Instructions:

** - Please also analyze for Rat/Mouse Allergens M245

Controlled Document – COC-34 Micro R7.2 8/23/2017

OrderID: 371823035

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Microbiology Chain of Custody

EMSL Order Number (*Lab Use Only*): 371823035

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Sample Location/Description	Sample Type	Potable/ NonPotable	Test Code	Volume/ Area	Date/Time Collected	Temperature (°C) (Lab Use Only)
BL	Blank	Air	☐P ☐NP	M001	0L	12-13-18	
ICR-CV1	Rm 405	Dust	☐P ☐NP	M044**	N/A	12-13-18	
ICR-CV2	5th Floor Conference Room	Dust	☐P ☐NP	M044**	N/A	12-13-18	
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				
			☐P ☐NP				

Comments/Special Instructions:

** - Please also analyze for Rat/Mouse Allergens M245