December 12, 2018

Clemson University
310 Klugh Avenue
Clemson, South Carolina 29634

Attn: Mr. W. Robert Newberry, IV
E-mail: wnewber@clemson.edu

Re: Limited Mold Investigation Report
Clemson University
Lightsey Bridge 1 Building 5 Apartment 1A
Clemson, South Carolina
Terracon Project No. 86187072Z

Dear Mr. Newberry:

Terracon Consultants, Inc. (Terracon) conducted a limited mold investigation in Lightsey Bridge 1 Building 5 Apartment 1A (Unit 5-1A) at Clemson University in Clemson, South Carolina. This service was conducted in general accordance with our Master Service Agreement with Clemson University.

PROJECT DESCRIPTION

Scope of Services

At the request of Clemson University, Terracon conducted a limited mold investigation in Lightsey Bridge 1, Unit 5-1A on October 3, 2018. Reportedly, water entered the bathroom of Unit 5-1A due to a leak in the unit above. The water was reportedly dried by Clemson University maintenance staff using fans and the vinyl wood flooring was replaced.

On our October 3rd visit, Terracon conducted airborne mold sampling (non-viable) which consisted of collecting spore trap air samples inside the apartment unit and the collection of two additional samples outside for comparison to verify mold spore levels.

Standard of Care

This limited mold and allergen investigation was conducted in a manner consistent with the level of care and skill ordinarily exercised by members of the profession currently practicing under similar conditions in the same locale. Terracon did not attempt to identify every potential exposure or hazard present in the subject building. The results, findings, conclusions and recommendations expressed in this report are based on conditions observed during our sampling. Many factors, such as weather conditions, building occupancy, ventilation patterns and seasonal variations in fungal concentrations, can affect the conditions observed. The information contained in this report should not be relied upon to represent conditions that existed prior to or after this sampling. Terracon does not warrant the services of regulatory agencies, laboratories or other third parties supplying information that may have been used in the preparation of this report.

SAMPLING CRITERIA AND METHODS

Mold Sampling

Total mold spore trap samples were collected using Air-O-Cell™ spore trap cassettes specifically designed for the collection of airborne mold spores. Air samples were collected using a calibrated Zefon Bio-Pump™ at a flow rate of 15 liters per minute (LPM) for 5 minutes at each location.

After collection, the spore trap samples were delivered via FedEx utilizing chain-of-custody procedures to EMSL Analytical, Inc. in Pineville, North Carolina. EMSL is accredited by the AIHA® Laboratory Accreditation Programs, LLC under the Environmental Microbiology Laboratory Accreditation Program (EMLAP), Accreditation #192283. Air samples were analyzed by direct microscopic examination and results are reported in spores per cubic meter of air (spores/m^3).

To help interpret the mold sampling results, we compared indoor air and outdoor air measurements. High variability in airborne fungal spore concentrations can exist in different geographic locations, during different seasons, and weather patterns, and over the course of a given day. As a general rule, indoor air fungal spore concentrations in a heating, ventilation and air-conditioning (HVAC)-supplied building are typically less than, but qualitatively similar to, fungal spore concentrations found in the outside environment.

No state or federal exposure limits have been established for fungal aerosols. Regulatory standards, medically based threshold limit or dose-response relationships have not been established for exposure to airborne or surface concentrations of mold spores. Terracon relies upon experience, professional judgment, current scientific literature, guidelines and recommendations made by professional organizations and experts, and statistical methods in interpreting mold sampling results.

FINDINGS

General Observations

- No evidence of mold growth or water intrusion was observed within the apartment unit (5-1A).
- The bathroom was finished with vinyl faux wood flooring and drywall ceiling & walls.

Non-Viable Mold Air Sampling

On the afternoon of October 3, 2018, Terracon collected one mold spore trap sample inside the building and two samples in outdoor locations for comparison. The results of the total spore count samples analyses are summarized in Table 1 below:

Table 1: Summary of Total Spore Count Analyses in the Air – October 3, 2018

Sample #	6910	8475	8469
Location Description	**Exterior 1**	**51-A Bathroom**	**Exterior 2**
Spore Type	**Spores/m^3**	**Spores/m^3**	**Spores/m^3**
Alternaria	40	-	40
Ascospores	1,400	40	910
Aspergillus/ Penicillium	40	540	450
Basidiospores	10,400	-	7,280
Cladosporium	950	40	910
Curvularia	100	-	40
Epicoccum	-	-	40
Ganoderma	30	-	-
Myxomycetes	200	-	200
Pithomyces	40	-	
Cercospora	40	-	40
Nigrospora	-	-	40
Torula-like	40	-	-
Total	**13,280**	**620**	**9,950**

The total mold spore levels indoors were lower than the outdoor levels. In general, the predominant mold type identified outdoors was Basidiospores while the predominant mold type identified indoors was Aspergillus / Penicillium. The laboratory analytical report is attached.

CONCLUSIONS

The following conclusions are provided based on our assessment:

- Based upon visual observations, Apartment 5-1A overall appeared to be clean with no signs of water intrusion or mold growth.
- Results of the spore trap sampling showed that the indoors had mold spores at a lower concentration compared to the outdoors. In general, the predominant mold type identified outdoors was Basidiospores while the predominant mold type identified indoors was Aspergillus/Penicillium. Although indoor Aspergillus / Penicillium type spores were predominant, they were not magnitudes (10-100 times) greater than outdoor levels. This is generally considered acceptable.

Terracon appreciates the opportunity to provide this service to Clemson University. If you have any questions regarding this limited mold and allergen investigation report, please contact the undersigned at 864-292-2901.

Sincerely,
Terracon Consultants, Inc.

Stephen Ellis
Staff Industrial Hygienist

FOR:
Jeffrey Gurrie, CIH
Senior Industrial Hygienist

Attachments: Laboratory Results

Laboratory Results

EMSL Analytical, Inc.

10801 Southern Loop Blvd Pineville, NC 28134
Tel/Fax: (704) 525-2205 / (704) 525-2382
http://www.EMSL.com / charlottelab@emsl.com

EMSL Order: 411808575
Customer ID: TERA62
Customer PO: 86187072Y
Project ID:

Attn: Scarlett Walden
Terracon Consultants, Inc.
2105 Newpoint Place
Suite 600
Lawrenceville, GA 30043
Project: 86187072Y - Lehotsky

Phone: (770) 623-0755
Fax: (770) 623-9628
Collected: 10/03/2018
Received: 10/05/2018
Analyzed: 10/05/2018

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	411808575-0001			411808575-0002			411808575-0003		
Client Sample ID:	2490-8524			2490-8471			2490-8483		
Volume (L):	75			75			75		
Sample Location	Exterior 1			102A			117		
Spore Types	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	3	100	1	-	-	-	-	-	-
Ascospores	25	1000	9.6	3	100	2.4	-	-	-
Aspergillus/Penicillium	13	540	5.2	54	2200	52.9	11	450	42.9
Basidiospores	178	7320	70	33	1400	33.7	12	490	46.7
Bipolaris++	-	-	-	1*	10*	0.2	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	29	1200	11.5	8	300	7.2	-	-	-
Curvularia	2	80	0.8	2*	30*	0.7	1*	10*	1
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	2	80	7.6
Myxomycetes++	1	40	0.4	1	40	1	-	-	-
Pithomyces++	1*	10*	0.1	1	40	1	-	-	-
Rust	1*	10*	0.1	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	2	80	0.8	1	40	1	1*	10*	1
Nigrospora	2*	30*	0.3	-	-	-	1*	10*	1
Pyricularia	1	40	0.4	-	-	-	-	-	-
Torula-like	1*	10*	0.1	-	-	-	-	-	-
Total Fungi	**259**	**10460**	**100**	**104**	**4160**	**100**	**28**	**1050**	**100**
Hyphal Fragment	1	40	-	1*	10*	-	1	40	-
Insect Fragment	2*	30*	-	-	-	-	-	-	-
Pollen	1*	10*	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

Lee Plumley, Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Pineville, NC AIHA-LAP, LLC - EMLAP 192283

Initial report from: 10/08/2018 06:46:47

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

EMSL Analytical, Inc.

10801 Southern Loop Blvd Pineville, NC 28134
Tel/Fax: (704) 525-2205 / (704) 525-2382
http://www.EMSL.com / charlottelab@emsl.com

EMSL Order: 411808575
Customer ID: TERA62
Customer PO: 86187072Y
Project ID:

Attn: Scarlett Walden
Terracon Consultants, Inc.
2105 Newpoint Place
Suite 600
Lawrenceville, GA 30043
Project: 86187072Y - Lehotsky

Phone: (770) 623-0755
Fax: (770) 623-9628
Collected: 10/03/2018
Received: 10/05/2018
Analyzed: 10/05/2018

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	411808575-0004			411808575-0005			411808575-0006		
Client Sample ID:	2490-8482			2490-6698			2490-6593		
Volume (L):	75			75			75		
Sample Location	131			207			221		
Spore Types	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	-	-	-	5	200	11.2	1	40	12.5
Aspergillus/Penicillium	5	200	28.6	6	200	11.2	2	80	25
Basidiospores	5	200	28.6	18	740	41.3	4	200	62.5
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	3	100	14.3	12	490	27.4	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	5	200	28.6	2	80	4.5	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	1	40	2.2	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	1	40	2.2	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-
Pyricularia	-	-	-	-	-	-	-	-	-
Torula-like	-	-	-	-	-	-	-	-	-
Total Fungi	**18**	**700**	**100**	**45**	**1790**	**100**	**7**	**320**	**100**
Hyphal Fragment	-	-	-	2	80	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	1	40	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.



Lee Plumley, Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Pineville, NC AIHA-LAP, LLC - EMLAP 192283

Initial report from: 10/08/2018 06:46:47

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

EMSL Analytical, Inc.

10801 Southern Loop Blvd Pineville, NC 28134
Tel/Fax: (704) 525-2205 / (704) 525-2382
http://www.EMSL.com / charlottelab@emsl.com

EMSL Order: 411808575
Customer ID: TERA62
Customer PO: 86187072Y
Project ID:

Attn: Scarlett Walden
Terracon Consultants, Inc.
2105 Newpoint Place
Suite 600
Lawrenceville, GA 30043
Project: 86187072Y - Lehotsky

Phone: (770) 623-0755
Fax: (770) 623-9628
Collected: 10/03/2018
Received: 10/05/2018
Analyzed: 10/05/2018

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	411808575-0007			411808575-0008			411808575-0009		
Client Sample ID:	2490-8502			2490-8498			2490-8463		
Volume (L):	75			75			75		
Sample Location	244			276B			Exterior 2		
Spore Types	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	2	80	5.8	-	-	-	21	860	9.2
Aspergillus/Penicillium	21	860	62.3	1	40	6.5	8	300	3.2
Basidiospores	6	200	14.5	3	100	16.1	139	5720	61.3
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	1*	10*	0.1
Cladosporium	6	200	14.5	4	200	32.3	28	1200	12.9
Curvularia	1	40	2.9	5	200	32.3	2	80	0.9
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	2	80	0.9
Myxomycetes++	-	-	-	-	-	-	19	780	8.4
Pithomyces++	-	-	-	1	40	6.5	1*	10*	0.1
Rust	-	-	-	1	40	6.5	1*	10*	0.1
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Cercospora++	-	-	-	-	-	-	4	200	2.1
Nigrospora	-	-	-	-	-	-	2	80	0.9
Pyricularia	-	-	-	-	-	-	-	-	-
Torula-like	-	-	-	-	-	-	-	-	-
Total Fungi	**36**	**1380**	**100**	**15**	**620**	**100**	**228**	**9330**	**100**
Hyphal Fragment	-	-	-	2*	30*	-	3	100	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	1	40	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	2	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.



Lee Plumley, Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Pineville, NC AIHA-LAP, LLC - EMLAP 192283

Initial report from: 10/08/2018 06:46:47

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

EMSL Analytical, Inc.

10801 Southern Loop Blvd Pineville, NC 28134

Tel/Fax: (704) 525-2205 / (704) 525-2382

http://www.EMSL.com / charlottelab@emsl.com

EMSL Order: 411809162
Customer ID: TERA62
Customer PO: 86187072Y
Project ID:

Attn: Scarlett Walden
Terracon Consultants, Inc.
2105 Newpoint Place
Suite 600
Lawrenceville, GA 30043
Project: Lehotsky - 10.11.18 - 86187072Y

Phone: (770) 623-0755
Fax: (770) 623-9628
Collected: 10/11/2018
Received: 10/12/2018
Analyzed: 10/12/2018

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	411809162-0001			411809162-0002			411809162-0003		
Client Sample ID:	1-8368			2-8347			3-8355		
Volume (L):	75			75			75		
Sample Location	Exterior 1			244			221		
Spore Types	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	65	2700	16.9	-	-	-	-	-	-
Aspergillus/Penicillium	6	200	1.3	3	100	13.2	-	-	-
Basidiospores	309	12700	79.7	15	620	81.6	9	400	87
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	7	300	1.9	-	-	-	1*	10*	2.2
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	1	40	0.3	-	-	-	-	-	-
Myxomycetes++	-	-	-	1	40	5.3	1	40	8.7
Pithomyces++	-	-	-	-	-	-	1*	10*	2.2
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-
Oidium	-	-	-	-	-	-	-	-	-
Total Fungi	**388**	**15940**	**100**	**19**	**760**	**100**	**12**	**460**	**100**
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

Lee Plumley, Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Pineville, NC AIHA-LAP, LLC - EMLAP 192283

Initial report from: 10/14/2018 08:57:26

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

EMSL Analytical, Inc.

10801 Southern Loop Blvd Pineville, NC 28134

Tel/Fax: (704) 525-2205 / (704) 525-2382

http://www.EMSL.com / charlottelab@emsl.com

EMSL Order: 411809162
Customer ID: TERA62
Customer PO: 86187072Y
Project ID:

Attn: Scarlett Walden
Terracon Consultants, Inc.
2105 Newpoint Place
Suite 600
Lawrenceville, GA 30043
Project: Lehotsky - 10.11.18 - 86187072Y

Phone: (770) 623-0755
Fax: (770) 623-9628
Collected: 10/11/2018
Received: 10/12/2018
Analyzed: 10/12/2018

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	411809162-0004			411809162-0005			411809162-0006		
Client Sample ID:	4-8366			5-8498			6-8494		
Volume (L):	75			75			75		
Sample Location	207			276B			131		
Spore Types	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	1	40	8.9	1	40	3.4	2	80	8.2
Aspergillus/Penicillium	-	-	-	15	620	52.1	-	-	-
Basidiospores	9	400	88.9	11	450	37.8	21	860	87.8
Bipolaris++	-	-	-	1	40	3.4	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	1	40	3.4	-	-	-
Curvularia	-	-	-	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	2*	30*	3.1
Pithomyces++	-	-	-	-	-	-	1*	10*	1
Rust	1*	10*	2.2	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	-	-	-
Oidium	-	-	-	-	-	-	-	-	-
Total Fungi	**11**	**450**	**100**	**29**	**1190**	**100**	**26**	**980**	**100**
Hyphal Fragment	-	-	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	-	-	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.

Lee Plumley, Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Pineville, NC AIHA-LAP, LLC - EMLAP 192283

Initial report from: 10/14/2018 08:57:26

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com

EMSL Analytical, Inc.

10801 Southern Loop Blvd Pineville, NC 28134
Tel/Fax: (704) 525-2205 / (704) 525-2382
http://www.EMSL.com / charlottelab@emsl.com

EMSL Order: 411809162
Customer ID: TERA62
Customer PO: 86187072Y
Project ID:

Attn: Scarlett Walden
Terracon Consultants, Inc.
2105 Newpoint Place
Suite 600
Lawrenceville, GA 30043
Project: Lehotsky - 10.11.18 - 86187072Y

Phone: (770) 623-0755
Fax: (770) 623-9628
Collected: 10/11/2018
Received: 10/12/2018
Analyzed: 10/12/2018

Test Report: Air-O-Cell(™) Analysis of Fungal Spores & Particulates by Optical Microscopy (Methods MICRO-SOP-201, ASTM D7391)

Lab Sample Number:	411809162-0007			411809162-0008			411809162-0009		
Client Sample ID:	7-8486			8-8367			9-8369		
Volume (L):	75			75			75		
Sample Location	117			102A			Exterior 2		
Spore Types	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**	**Raw Count**	**Count/m³**	**% of Total**
Alternaria (Ulocladium)	-	-	-	-	-	-	-	-	-
Ascospores	1	40	4	3	100	5.2	21	860	8.4
Aspergillus/Penicillium	8	300	29.7	8	300	15.7	-	-	-
Basidiospores	16	660	65.3	36	1500	78.5	226	9300	90.5
Bipolaris++	-	-	-	-	-	-	-	-	-
Chaetomium	-	-	-	-	-	-	-	-	-
Cladosporium	-	-	-	1*	10*	0.5	3	100	1
Curvularia	1*	10*	1	-	-	-	-	-	-
Epicoccum	-	-	-	-	-	-	-	-	-
Fusarium	-	-	-	-	-	-	-	-	-
Ganoderma	-	-	-	-	-	-	-	-	-
Myxomycetes++	-	-	-	-	-	-	-	-	-
Pithomyces++	-	-	-	-	-	-	-	-	-
Rust	-	-	-	-	-	-	-	-	-
Scopulariopsis/Microascus	-	-	-	-	-	-	-	-	-
Stachybotrys/Memnoniella	-	-	-	-	-	-	-	-	-
Unidentifiable Spores	-	-	-	-	-	-	-	-	-
Zygomycetes	-	-	-	-	-	-	-	-	-
Nigrospora	-	-	-	-	-	-	1*	10*	0.1
Oidium	-	-	-	-	-	-	1*	10*	0.1
Total Fungi	**26**	**1010**	**100**	**48**	**1910**	**100**	**252**	**10280**	**100**
Hyphal Fragment	1*	10*	-	-	-	-	-	-	-
Insect Fragment	-	-	-	-	-	-	-	-	-
Pollen	-	-	-	1	40	-	-	-	-
Analyt. Sensitivity 600x	-	41	-	-	41	-	-	41	-
Analyt. Sensitivity 300x	-	13*	-	-	13*	-	-	13*	-
Skin Fragments (1-4)	-	1	-	-	1	-	-	1	-
Fibrous Particulate (1-4)	-	1	-	-	1	-	-	1	-
Background (1-5)	-	1	-	-	1	-	-	1	-

++ Includes other spores with similar morphology; see EMSL's fungal glossary for each specific category.

No discernable field blank was submitted with this group of samples.



Lee Plumley, Laboratory Manager
or other approved signatory

High levels of background particulate can obscure spores and other particulates leading to underestimation. Background levels of 5 indicate an overloading of background particulates, prohibiting accurate detection and quantification. Present = Spores detected on overloaded samples. Results are not blank corrected unless otherwise noted. The detection limit is equal to one fungal spore, structure, pollen, fiber particle or insect fragment. "*" Denotes particles found at 300X. "-" Denotes not detected. Due to method stopping rules, raw counts in excess of 100 are extrapolated based on the percentage analyzed. EMSL maintains liability limited to cost of analysis. This report relates only to the samples reported above and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. Interpretation and use of test results are the responsibility of the client. Samples received in good condition unless otherwise noted.

Samples analyzed by EMSL Analytical, Inc. Pineville, NC AIHA-LAP, LLC - EMLAP 192283

Initial report from: 10/14/2018 08:57:26

For information on the fungi listed in this report, please visit the Resources section at www.emsl.com